

# North Sagamore Water District

## 2014 Annual Water Quality Report

PWS ID # 4036002

### **Board of Water Commissioners:**

*Mark Bergeron-Chairman*

*Mark Melchionda*

*George M. Sala*

### **Who to Call:**

*water problems,*

*meter problems, leaks,*

*fire hydrants, billing,*

*water quality, main breaks,*

*misc. questions call*

*(508) 888-1085*

### **Emergency:**

*for water problems out-*

*side of normal working*

*hours, please call*

*(508) 888-1085 and press*

*3 or Bourne Police*

*at (508) 759-4453*

The North Sagamore Water District holds monthly Commissioner's meetings the third week of each month. The meetings are held at the District Office on 14 Squanto Road, Sagamore Beach, MA and begin at 4:00pm unless posted otherwise. These meetings are posted publicly and the public is encouraged to participate. Our office is open Monday thru Friday from 7:30am to 4:00pm.

Our water system is routinely inspected by the Department of Environmental Protection (DEP). The DEP inspects our system for its technical, financial and managerial capacity to provide safe drinking water to you. To ensure that we provide the highest quality of water available, your water system is operated by Massachusetts certified operators who oversee the routine operations of our system. In 2014 the District updated our SCADA system, procured a generator for our wells, has continued updating our meter reading system and began reading meters bi-annually.

### **Drinking Water Sources**

The North Sagamore Water District is currently supplied by three active gravel-packed wells that withdraw our drinking water from the Plymouth/Carver Aquifer. Last year the District pumped 151 million gallons of water from these sources. Black Pond Well (installed in 1979) located on Black Pond Road and Church Lane Well (built in 2001) feed into the James A. Morgan Water Treatment Plant also located on Church Lane. At this location the water is treated with potassium permanganate to oxidize iron and manganese, sodium hydroxide to reduce lead and copper concentrations within the water system and a low dose of sodium hypochlorite to eliminate bacteria throughout the distribution system all before being filtered to remove iron and manganese. The Beach Well (installed in 1958) located on Pilgrim Road is treated only with sodium hydroxide to reduce lead and copper concentrations. The District currently does not have an emergency interconnection with any other district or town. Future connections with neighboring water systems may be possible for a backup supply. The District has three above ground storage tanks, Bournedale Tank (located along the Scenic Highway), Clark Road Tank and Norris Road Tank, with a total storage of 1.7 million gallons of water. The District also operates two booster pumping stations in order to supply increased pressures and flows to certain neighborhoods off of Old Plymouth Road, State Road and Norris Road as well as Weldon Park.

### **WATER CONSERVATION PROTECTS OUR NATURAL RESOURCES**

Your commitment to conserving our drinking water is greatly appreciated, especially during the outside water use periods of May through September. Non-essential outside watering should be limited to two days a week and done in the early morning or evening hours. Customers with irrigation systems are strongly urged to install rain or moisture gauges on their systems, as most lawns only require one inch of rain weekly. The District has conservation information and tools including rain gauges and low-flow hand held hose nozzles available at our office as well as low-flow shower heads offered at cost to residents of the District.

### **Source Water Assessment Program Report**

The Department of Environmental Protection (DEP) has prepared a Source Water Assessment Program Report (SWAP) for the water supply sources serving the North Sagamore Water District. The SWAP Report summarizes the potential sources of contamination within the water supply protection area

for the Black Pond Well, Church Lane Well and the Beach Well. A susceptibility rating of high was assigned to this system using the information collected during the assessment by the DEP.

The SWAP report commends the District for:

- Working with the towns of Bourne and Plymouth to protect the public wells
- Conducting public outreach efforts; and
- Purchasing land for water supply protection

The SWAP report recommends these actions to better protect our water sources for the future:

- Continuing to inspect the Zone 1 regularly
- Educate residents on the ways they can help to protect drinking water sources
- Work with emergency response teams to ensure that they are aware of the storm water drainage in your Zones I & II and to cooperate on responding to spills or accidents

The North Sagamore Water District addresses the protection recommendations by increased monitoring of drinking water protection areas and focusing on best management practices to improve our water supply protection. Copies of this report are on file at the District Office and available on our website.

### **Substances Found in Tap Water**

Sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of some contaminants does not necessarily indicate that the water poses a health risk.

Contaminants that may be present in source water before treatment include: **microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife. **Inorganic contaminants**, such as salts and metals, can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming. **Pesticides and herbicides** may come from a variety of sources such as agriculture, storm water runoff and residential uses. **Organic chemical contaminants** include synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff and septic systems. **Radioactive contaminants** can be naturally occurring or be the result of oil and gas production, and mining activities.

In order to ensure that tap water is safe to drink, the Mass DEP and the EPA prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) and the Massachusetts Department of Public Health (DPH) regulations establish limits for contaminants in bottled water that must provide the same protection for public health.

*\*Some people may be more vulnerable to contaminants in drinking water than general population. Immune compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care providers.*

### **Important Definitions**

**MCLG:** Maximum contaminant level goal, or the level of a substance in drinking water below which there is no known or expected health risk. MCLG's allow for a margin of safety.

**MCL:** Maximum contaminant level or the highest level of substance that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology

**ppm:** parts per million    **ppb:** parts per billion    **ND:** not detected    **AL:** Action Level

**Action Level:** The concentration of a contaminant, if exceeded, triggers treatment or other requirements by district

**90th %** - out of 10 homes sampled, 9 were at or below this level

**2014 WATER QUALITY TESTING RESULTS**  
Zero (0) Violations

**Inorganic Contaminants- ppm**

<u>Contaminant</u>	<u>MCL</u>	<u>MCLG</u>	<u>Detected Level</u>	<u>Range of Levels</u>	<u>Sample Date</u>	<u>Major Sources</u>
Nitrate	10	10	3.4	0.26-3.4	6/17/2014	Run off from Fertilizer use/ Septic Systems
Perchlorate	2	N/A	0.07	0.05-0.07	8/27/2014	Fireworks, Munitions, Flares

**Disinfection By-Products- ppb**

Total Haloacetic Acids	60	0	1.6	0.63-1.6	8/20/2014	By-product of Chlorination
Total Trihalo-Methanes	80	0	2.8	0-2.8	8/26/2014	By-product of Chlorination

**Lead and Copper**

<u>Contaminant</u>	<u>AL</u>	<u>MCLG</u>	<u>90th % Level</u>	<u>Range of Levels</u>	<u>Sites above AL</u>	<u>Major Sources</u>
Lead (ppb)	15	0	0.000	0-3	0 out of 20	Household Plumbing Corrosion
Copper (ppm)	1.3	0	0.28	0.0049-0.38	0 out of 20	Household Plumbing Corrosion

**Testing Dates for Above Lead & Copper- 9/10/2014-9/29/2014**

*If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. North Sagamore Water District is responsible for providing high quality water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://epa.gov/safewater/lead>.*

**Secondary and Unregulated Contaminants**

Unregulated contaminants are those for which there are no established drinking water standards. The purpose of unregulated contaminant monitoring is to assist regulatory agencies in determining their occurrence in drinking water and whether future regulation is warranted.

<u>Contaminant</u>	<u>Date Collected</u>	<u>Range Detected</u>	<u>Average Detected</u>	<u>SMCL</u>	<u>Guideline or Health Advisory</u>	<u>Possible Sources</u>
Manganese (ppb)	6/19/2014	ND-12	6	50 *	300	Erosion of natural Deposits
Sodium (ppm)	5/7/2012	54	54	N/A	20**	Natural deposits / Treatment By-product

\* **Secondary Maximum Contaminant Level** : Guidance values issued by US EPA representing levels and parameters above which aesthetic properties of water can be affected (taste, odor, color) or cosmetic effects may occur (skin or tooth discoloration).

\*\* Sodium is a naturally occurring common element found in soil and water and is necessary for functioning of human systems. The guideline of 20 ppm when exceeded does not require treatment to reduce levels, rather represents the level of sodium in water that physicians and sodium sensitive individuals should be aware of where sodium exposures are being carefully controlled. More information on sodium is available at our office and on our website.

**Fluoride:** The North Sagamore Water District does **not** add fluoride to the water and testing of source water detects none.

**Chlorination:** In 2014, the average monthly free chlorine residuals within the distribution system ranged from 0.20 ppm to 0.30 ppm, well below the MCL of 4.0 ppm.

**\*The North Sagamore Water District's drinking water meets or exceeds all Federal and State drinking water standards as required by law.\***

The North Sagamore Water District tests its drinking water supply as required by the Department of Environmental Protection. The results are sent to the D.E.P. monthly for their review. Should any of our tests indicate any irregularities, we would be notified immediately. In turn, the District would immediately notify its customers. The resources currently used by the District to inform customers of any testing results, water conservation recommendations, flushing, etc. are:

- Our website: [www.northsagamorewaterdistrict.com](http://www.northsagamorewaterdistrict.com)
- The Bourne Enterprise News Paper
- Bourne Community Television

The District is continually striving to meet the challenges of complying with the Safe Drinking Water Act. It is the goal of this District's Commissioners and staff to ensure our customers the highest level of water quality possible.

More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency Safe Drinking Water Hotline (1-800-426-4791) or by visiting the following websites

- [www.mass.gov/eea/agencies/massdep/water/drinking/](http://www.mass.gov/eea/agencies/massdep/water/drinking/) - Mass. D.E.P.
- [www.epa.gov/ogwdw](http://www.epa.gov/ogwdw) - Environmental Protection Agency Website

**Cross Connection & Backflow Protection**

Help protect your public water supply and safeguard your potable water use from contamination due to backflow and back-siphonage. When water flows backwards through the water supply system, backflow and back-siphonage can occur. Numerous well documented cases identify that cross connections have been responsible for contamination of drinking water. A cross connection is identified as any actual or potential connections between a potable and non potable water supply. **How you can help:** Never submerge hoses in containers including pools, buckets, tubs and or sinks. Always keep the end of the hose clear of possible contaminants. Inexpensive backflow devices can be purchased and easily installed on all of your older style hose bibs or threaded faucets. Customers with irrigation systems should make sure their backflow prevention devices are properly working. The District needs your support in helping to maintain a safe delivery of our drinking water system. More information on cross connections is available at our office.

**Questions regarding this report:** Any questions pertaining to this report may be directed to Superintendent, Matthew Sawicki at (508) 888-1085 or email at [matt-nswd@comcast.net](mailto:matt-nswd@comcast.net).



[www.northsagamorewaterdistrict.com](http://www.northsagamorewaterdistrict.com)